

london-fire.gov.uk

The Company Secretary
Mame Limited
585a Fulham Road
London
SW6 5UA

The London Fire Commissioner is the fire and rescue authority for London

Date 6 October 2022 Our Ref 11/223366/PG

Dear Sir/Madam

REGULATORY REFORM (FIRE SAFETY) ORDER 2005 (AS AMENDED): NOTIFICATION OF FIRE SAFETY DEFICIENCIES

Premises: Shop, 1a Eyot Gardens, London, W6 9TN

The London Fire Commissioner (the Commissioner) is the fire and rescue authority for London. The Commissioner is responsible for enforcing the Regulatory Reform (Fire Safety) Order 2005 (as amended) hereafter the Fire Safety Order (as amended) in London.

The Commissioner's Inspectors have recently carried out an inspection of the above mentioned premises. During the inspection, it was noted that some fire safety matters require attention to reduce the risk of fire and/or reasonably ensure the safety of people using the premises. These matters need to be addressed in order to comply with the Fire Safety Order (as amended).

The matters that need to be addressed, together with the Commissioner's recommendations about the actions you should take are explained in the attached schedule. We recommend that action should be taken by **29 December 2022**.

If you are in any doubt about what you need to do to comply with the Fire Safety Order (as amended); or if there is anything in the schedule that you do not understand or need further explanation of then please contact the Inspector named at the end of this letter. If you are dissatisfied in any way with the response given please ask to speak to the Team Leader quoting the above reference.

You may also wish to know that fire safety guidance for businesses can be found on the Commissioner's website at www.london-fire.gov.uk under the heading 'Fire safety at work'. Additionally, guidance on general fire precautions and how to comply with the Fire Safety Order (as amended) can be found at www.Gov.uk under the heading 'Fire safety law and guidance documents for business'.

When undertaking fire safety works at your premises you may need to seek approval for what you are going to do. Examples of this would include:

- any building works for which you are obliged to notify or seek the approval of Building Control;
- if your premises have a listed heritage status, approval from the local authority conservation officer; or
- if your premises are licenced then you may need to consult the relevant licensing or approvals authority.
- It is your responsibility to consult the relevant bodies and obtain any necessary approvals.

I would ask you to note that as well as placing people at risk, operating premises without having adequate general fire precaution in place to remove or reduce fire risk and to ensure people can safely escape if a fire does occur can result in a criminal offence being committed. This letter and its associated schedule are consequently issued without prejudice to any legal action the Commissioner may subsequently take regarding failures to comply with the Fire Safety Order (as amended).

Yours faithfully

PP Peter Godfrey

for Assistant Commissioner (Fire Safety)

Directorate of Operations FSR-AdminSupport@london-fire.gov.uk

Reply to Fire Safety Advisor Alfie Whitbread

Enc: Form FS03_01b Legislation Extracts

Form FS03_06 Definitions of standard terms

Cc: Licensing Team, London Borough of Hammersmith and Fulham: licensing@lbhf.gov.uk

Notes to accompany the Notification of Deficiencies schedule.

<u>Important information to consider before taking remedial steps:</u>

- 1. Certain terms written in BLOCK CAPITALS in the attached schedule are standard terms defined in "Definitions of standard terms used in means of escape requirements" which form part of this schedule.
- 2. Officers of the Commissioner may visit your premises again to check on the action you have taken.
- 3. Notwithstanding any consultation undertaken by the Commissioner, before you make any alterations to the premises, you must apply for local authority building control department approval (and/or the approval of any other bodies having a statutory interest in the premises) if their permission is required for those alterations to be made.
- 4. There may be suitable alternative safety measures to those detailed in this schedule, which would meet the requirements of the Order. If you wish to propose or discuss any alternative measures you should get in touch with the person named as the contact above, before you take any action, to ensure that your proposed measures are deemed satisfactory by the Commissioner.
- 5. Remedial steps must be undertaken by a competent person who has sufficient training, experience, knowledge or other qualities to enable him or her to properly undertake them.
- 6. We recommend that remedial steps are undertaken in accordance with the appropriate British or European Standards, or recognised industry guidance.

THE REGULATORY REFORM (FIRE SAFETY) ORDER 2005

Your rights when Fire Safety Inspecting Officers take action.

The Commissioner has a duty to enforce the Regulatory Reform (Fire Safety) Order 2005.

If an Inspector:

tells you to do something - you have a right to a verbal and written explanation of what needs to be done and why.

Intends to take immediate action - for example by issuing an enforcement notice this will include a written explanation either forming part of the notice or by separate letter.

Issues a formal notice - you will be told in writing about your right to appeal to a magistrates' court. You will be told:

- how to appeal;
- where and within what period an appeal may be brought; and
- that action required by a prohibition/restriction notice is not suspended while an appeal is pending unless the court so directs.
- that action required by an enforcement notice is suspended while an appeal is pending.

Issues a Notification of Fire Safety Deficiencies - <u>full discussion should have taken place and agreed improvements to bring the premises up to minimal standards should be formulated. A Notification is a notification of the premise of the prem</u>

of Fire Safety Deficiencies carries no statutory force but may result in formal action being considered if the agreed improvements do not take place.

The procedures and rights above provide ways for you to have your views heard. If you are not happy with the inspecting officer's action you should contact the Team Leader on the telephone number shown at the head of the covering letter in the first instance.

ENVIRONMENT AND SAFETY INFORMATION ACT 1988 SECTION 4 - PROTECTION OF TRADE SECRETS

The above Act requires the London Fire Commissioner to maintain public registers of notices issued under Article 30 of the Regulatory Reform (Fire Safety) Order 2005, (other than those which impose requirements or prohibitions solely for the protection of persons at work) and Sections 21 and 22 of the Health and Safety at Work etc, Act 1974.

Provisions are made within the Act for persons on whom the above notices are served to appeal against any proposed entry in the register which may disclose "trade secrets" or "secret manufacturing processes".

Entries in the register are required to be made after the period for appeal against the notice expires or after any appeal is disposed of.

If you feel that any such entry would disclose information about a trade secret or secret manufacturing process you may write to the Commissioner within a period of 14 days following the service of the notice, requesting exclusion of these details (see Section 4 of the 1988 Act).

SCHEDULE

PREMISES: Shop, 1a Eyot Gardens, London, W6 9TN

FILE NUMBER: 11/223366

This schedule should be read in conjunction with the Commissioner's letter dated 6 October 2022.

The condition(s) specified in the Regulatory Reform (Fire Safety) Order 2005, were being contravened and the following step(s) need(s) to be taken in order to comply with the above legislation:

Article	Area of Concern	Steps Considered necessary to remedy the contravention.
Article 10	At the time of the audit the risk reduction and prevention principles of the Order had not been applied in the correct sequence. It was found that:	Apply the principles of prevention contained in schedule 1 part 3 of the Order in the priority set out in that schedule. In particular ensuring all electrical appliances and electric caballing in the premises are reviewed by a competent person.
	1) There was evidence of multiple electrical cables in the kitchen storage area, and it has not been controlled.	
	2) The canopy outside had a mixture of electrics with rainwater dripping near the socket and it has not been controlled to ensure the safety of all relevant persons.	
	3) There was evidence of a burnt extension cable where the CCTV monitor is located with overloaded plugs. This has to be removed and replaced with suitable wall plugs and have all electrics assessed by a competent electrician or contractor.	
Article 11	At the time of the audit your preventative and protective measures had not been planned, organised, controlled, monitored or reviewed where required. It was found that:	Arrangements identified as not suitably addressed must be effectively planned, organised, controlled, monitored or reviewed.
	1) Nominating fire marshals has not effectively been planned or organised.	

Article 11 (Cont'd)	 2) Management controls of overloaded electrical appliances have not effectively been controlled, monitored or reviewed. 3) The 5 year electrical wiring survey has not effectively been planned or organised. 	
	4) Basic fire safety awareness training given to staff has not effectively been controlled, monitored or reviewed.	
Article 15	At the time of the audit your procedures to be followed in the event of serious and imminent danger were inadequate. It was found that sufficient numbers of competent persons had not been nominated to act as fire wardens.	Adequate procedures for serious and imminent danger and for danger areas should be established and followed. This can be achieved by nominating and training suitable persons to carry out the duties of a fire warden.
Article 21	At the time of the audit your employees had not been provided with adequate safety training. It was found that new/existing employees had not been given appropriate training on the precautions to be taken in the event of an emergency.	Provide your staff with adequate safety training. In particular new/existing employees should be given appropriate fire safety training including procedures for emergency evacuation.
Article 9	At the time of the audit the fire risk assessment for your premises has not been subject to a suitable system of review. It was found that:	The fire risk assessment should be reviewed.
	1) The compartmentation between the commercial restaurant and the single private dwelling above has not been risk assessed to confirm the level of 60 minute FIRE RESISTING construction.	
	2) A 5 year electrical wiring survey has not been carried out, i.e. overloaded plug socks with caballing running throughout the premises.	

RECOMMENDATIONS NOT FORMING REQUIREMENTS OF THE SCHEDULE

The Commissioner would strongly urge that you consider the presence of combustible façade cladding materials as part of the risk assessment process for these premises. All relevant information about any replacement window and facade schemes should be made fully available to fire risk assessors. Where no reliable information is available for a given property, a strategy to assess the risk and where necessary implement short, medium and long term actions to address the risk should be implemented.

Where remedial measures are to be undertaken to which consultation requirements under Section 20 of the Landlord and Tenant Act 1985 will apply, the Commissioner would urge you to consider application of the disapplication provisions under Section 20ZA of that Act.